


AWS D1.2/D1.2M:2008
An American National Standard



Structural Welding Code— Aluminum



American Welding Society



**AWS D1.2/D1.2M:2008
An American National Standard**

**Approved by the
American National Standards Institute
June 23, 2008**

Structural Welding Code— Aluminum

Fifth Edition

Supersedes AWS D1.2/D1.2M:2003

Prepared by the
American Welding Society (AWS) D1 Committee on Structural Welding

Under the Direction of the
AWS Technical Activities Committee

Approved by the
AWS Board of Directors

Abstract

This code covers the welding requirements for any type structure made from aluminum structural alloys, except for aluminum pressure vessels and pressure piping. Clauses 1 through 7 constitute a body of rules for the regulation of welding in aluminum construction. A commentary on the code is also included with the document.



American Welding Society

550 N.W. LeJeune Road, Miami, FL 33126

Dedication

In Memoriam

Paul B. Dickerson
1926–2004

This issue of AWS D1.2, *Structural Welding Code—Aluminum*, is dedicated to the memory of Paul B. Dickerson. Paul was instrumental in the inception of the first *Structural Welding Code—Aluminum* and a moving force in its growth over the years. Paul was an internationally renowned engineer, as well as an educator and mentor to many in the welding community. He was always ready to share his almost immeasurable expertise with anyone who needed help. His good nature and humor made it a joy to work with him.

Paul will be greatly missed by all of us.

Foreword

This foreword is not part of AWS D1.2/D1.2M:2008, *Structural Welding Code—Aluminum*, but is included for informational purposes only.

In the early 1970s, interest was expressed in developing a consolidated code for the structural welding of aluminum similar to the AWS D1.1, *Structural Welding Code—Steel*. Because of the interest of both The Aluminum Association and the American Welding Society, it was decided to begin in the mid-70s the task of developing a structural welding code for aluminum. Initially, the effort was undertaken by a task force of The Aluminum Association. In 1979, this task force became a subcommittee of the AWS Structural Welding Committee and the *Structural Welding Code—Aluminum* resulted from the continued activity of that subcommittee.

The first edition of the *Structural Welding Code—Aluminum* (hereafter referred to as the *code*) represented the continuing AWS policy to provide standards for structural welding. This code is provided for the fabrication, erection and manufacturing industries as a set of rules and regulations for the welding of structural aluminum. Some of the more important aspects of this edition of the code are outlined in the following paragraphs.

Recommended joint details have been prepared for numerous complete joint penetration groove welded joints. Herein lies one of the major differences between the *Structural Welding Code—Steel* and this code. While the steel code allows for prequalified welding procedures, this code does not. This is mainly because of the many and varied possible welding conditions that can be obtained with semiautomatic welding variables most often used with aluminum and the wide range of both heat-treatable and nonheat-treatable alloys that may be welded under this code. Therefore, all of the joint details and the welding procedures used with this code shall be individually qualified and included in the Welding Procedure Specification (WPS).

Procedures and standards are outlined for several methods of nondestructive testing. Methods included are visual, radiographic and dye-penetrant. Ultrasonic testing is permitted, but the procedure and acceptance criteria shall be specified in the contract documents.

This code does not concern itself with such design considerations as the arrangements of parts, loading, and the computation of stresses for proportioning the load-carrying members of a structure and their connection. Such considerations, it is assumed, are covered elsewhere in a general code or specification, such as the *Specification for Aluminum Structures* (The Aluminum Association).

Many of the users of this code will also be users of the *Structural Welding Code—Steel*. As a result, it was felt that as much similarity as possible between the codes for steel and aluminum should be achieved. Thus, the same general format was used in the development of the 1983 and 1990 editions of the aluminum code as in the steel code. The D1.2-97 code was reorganized so that the 1990 Clauses 4 and 5 (Technique and Qualification) were merged into one new Clause 4. Furthermore, Appendix H of D1.2-90 was moved to after the Preface. Clauses 1 through 7 constitute a body of rules for the regulation of welding on aluminum structures. The 2003 edition represented a major reorganization of the D1.2-97 format. For example, Clauses 7, 8, and 9 of D1.2-97 were eliminated, and their provisions distributed throughout the code.

In this edition of D1.2/D1.2M:2008, the following major revisions have been made:

- (1) Addition of design criteria for PJP groove welds for GTAW and GMAW.
- (2) Addition of new alloys in Tables 3.2, 4.2, 6.2, and 6.3; new materials in Table 4.1.
- (3) Revision of positions qualified in Table 3.3 for Pipe-Groove CJP.
- (4) Modifications made to Figure 3.18.

- (5) Addition of new Table 4.6 for Weld Appearances.
- (6) Inclusion of acceptance criteria for RT in tubular connections in 5.15.2.
- (7) Deletion of Table 5.3, Acceptable Undercut Values; Table 5.5, Acceptance Criteria—Class I Structures; Table 4.6, Acceptance Criteria—Class II Structures; and Table 4.7, Maximum Acceptable Porosity in Radiographs for Any 3 in Length Weld.
- (8) Figure 5.8 extensively modified and renamed as Maximum Acceptable Discontinuities RT Images.
- (9) Deletion of Figure 5.9, Acceptable Undercut for Total Length of Joint—Class I Tubular Structures.
- (10) Inclusion of recommended partial penetration groove welded joints in Annex B.
- (11) Deletion of Annex L, Reorganization.
- (12) Removal of Commentary C-4.19 and C-5.14.
- (13) Addition of visual radiography standards.
- (14) Inclusion of standards for visual inspection of surface porosity.

All editorial and technical changes to the text are indicated by underlining. Changes to illustrations are indicated by a single vertical line.

Commentary. The Commentary is nonmandatory and is intended only to provide insightful information into provision rationale.

Normative Annexes. These annexes address specific subjects in the code and their requirements are mandatory requirements that supplement the code provisions.

Informative Annexes. These annexes are not code requirements but are provided to clarify code provisions by showing examples, providing information, or suggesting alternative good practices.

Index. As in previous codes, the entries in the Index are referred to by subclause number rather than by page number. This should enable the user of the Index to locate a particular item of interest in minimum time.

Errata. It is the Structural Welding Committee's policy that all errata should be made available to users of the code. Therefore, any significant errata will be published in the Society News Section of the *AWS Welding Journal* and posted on the AWS web site at: <http://www.aws.org/technical/d1/>.

Suggestions. Your comments for improving AWS D1.2/D1.2M:2008, *Structural Welding Code—Aluminum*, are welcome. Submit comments to the Managing Director, Technical Services Division, American Welding Society, 550 N.W. LeJeune Road, Miami, FL 33126; telephone (305) 443-9353; fax (305) 443-5951; e-mail info@aws.org; or via the AWS web site <<http://www.aws.org>>.

Table of Contents

	Page No.
<i>Dedication</i>	v
<i>Personnel</i>	vii
<i>Foreword</i>	ix
<i>List of Tables</i>	xiv
<i>List of Figures</i>	xv
1. General Requirements	1
1.1 Scope	1
1.2 Approval	1
1.3 Definitions	1
1.4 Welding Symbols	1
1.5 Safety Precautions	1
1.6 Standard Units of Measure	1
1.7 Reference Documents	1
2. Design of Welded Connections	3
2.0 Scope	3
2.1 Structural Design	3
2.2 Drawings	3
2.3 Groove Welds	4
2.4 Fillet Welds	4
2.5 Plug and Slot Welds	5
2.6 Filler Plates	5
3. Qualification	9
Part A—General Requirements	9
3.1 General	9
3.2 Qualification of WPSs	9
3.3 Qualification of Welders, Welding Operators, and Tack Welders	10
3.4 Position of Test Welds	10
Part B—Types of Tests, Test Methods, and Acceptance Criteria	11
3.5 Types and Purposes of Tests	11
3.6 Visual Examination	11
3.7 Tension Tests—Groove Welds	12
3.8 Bend Tests—Groove Welds—Plate and Pipe	12
3.9 Soundness Tests—Groove Welds in Castings	14
3.10 Soundness Tests—Fillet Welds	14
3.11 <u>Radiographic Examination</u>	15
Part C—WPS Qualification	15
3.12 General	15
3.13 Limits of Qualified Positions for WPSs	15
3.14 Limitation of Essential Variables—WPS Qualification	15
3.15 Tests—WPS Qualification	15
3.16 Retests	16
Part D—Performance Qualification	16
3.17 General	16
3.18 Limits of Qualified Positions for Performance	17

3.19	Preparation of Test Weldments—Performance Qualification	17
3.20	Essential Variables.....	18
3.21	Tests—Performance Qualification	18
3.22	Retests.....	18
3.23	Period of Effectiveness	19
4.	Fabrication	65
4.0	Scope.....	65
4.1	Processes.....	65
4.2	Base Metal	65
4.3	Filler Metal	65
4.4	Tungsten Electrodes.....	65
4.5	Shielding Gas.....	65
4.6	Welding and Cutting Equipment	65
4.7	Backing	66
4.8	Preheat and Interpass Temperatures	66
4.9	Welding Environment.....	66
4.10	Compliance with Design.....	66
4.11	Preparation of Base Metal	66
4.12	Assembly	67
4.13	Technique	68
4.14	Tack and Temporary Welds.....	68
4.15	Dimensional Tolerances for Welded Members	68
4.16	Arc Strikes	69
4.17	Weld Termination.....	69
4.18	Control of Distortion and Shrinkage.....	69
4.19	Weld Profiles	70
4.20	Repairs	70
4.21	Copper Inclusions	71
4.22	Cleaning of Completed Welds.....	71
4.23	Anti-Spatter Compound.....	71
4.24	Postweld Heat Treatment.....	71
5.	Inspection	79
	Part A—General Requirements.....	79
5.1	General.....	79
5.2	Inspection of Materials	80
5.3	Inspection of WPS Qualification and Equipment.....	80
5.4	Inspection of Welder, Welding Operator, and Tack Welder Qualifications	80
5.5	Inspection of Work and Records	80
5.6	Obligations of the Contractor	80
5.7	Nondestructive Testing.....	81
5.8	Extent of Testing.....	81
	Part B—Radiographic Testing of Groove Welds in Butt Joints	82
5.9	General.....	82
5.10	RT Procedures	82
5.11	Acceptability of Welds	84
5.12	Examination, Report, and Disposition of Radiographs	84
	Part C—Ultrasonic Testing of Groove Welds.....	84
5.13	General.....	84
	Part D—Acceptance Criteria.....	85
5.14	Visual Inspection	85
5.15	RT	85

	Page No.
5.16 UT	86
5.17 PT	86
6. Stud Welding	97
Part A—General Requirements	97
6.1 General	97
6.2 Material Requirements	97
6.3 Workmanship	97
6.4 Qualification Requirements	97
6.5 Operator and Preproduction Qualification	99
6.6 Acceptance Criteria—Production Welds	99
6.7 Mislocated Studs	99
6.8 Repair of Misapplied Studs	99
Part B—Arc Stud Welding	99
6.9 General Requirements	99
6.10 Material Requirements	99
6.11 Workmanship	99
6.12 Technique	100
Part C—Capacitor Discharge Stud Welding	100
6.13 General Requirements	100
6.14 Material Requirements	100
6.15 Technique	100
7. Strengthening and Repair of Existing Structures	105
7.1 General	105
7.2 Base Metal	105
7.3 Design	105
7.4 Repair Procedure	105
7.5 Inspection	105
Annex A (Informative)—Reference Documents	107
Annex B (Informative)—Recommended Groove Welded Joints	109
Annex <u>D</u> (Informative)—Examples of Tubular Connections	145
Annex <u>E</u> (Informative)—Effective Throat	149
Annex <u>F</u> (Informative)—Sample Welding Forms	151
Annex <u>G</u> (Informative)—Sample NDT Forms	159
Annex <u>H</u> (Informative)—Solutions for Macroetching Aluminum Weldments	163
Annex <u>I</u> (Informative)—Guide for Specification Writers	165
Annex <u>J</u> (Informative)—Safe Practices	167
Annex <u>K</u> (Informative)—Tungsten Electrodes	171
Annex <u>L</u> (Informative)—Guidelines for the Preparation of Technical Inquiries	173
<i>Commentary</i>	175
Foreword	177
Index	201
List of AWS Documents on Structural Welding	209

List of Tables

Table	Page No.
2.1 Minimum Diameter of Hole for Plug Welds or Width of Slot for Slot Welds	6
3.1 Limitations of Essential Variables of a WPS	20
3.2 Tensile Strength of Welded Aluminum Alloys (GTAW or GMAW with No Postweld Heat Treatment)	22
3.3 WPS Qualification—Type of Weld and Position Limitations	24
3.4 Number and Type of Test Specimens and Range of Thickness Qualified—WPS Qualification—CJP Groove Welds	25
3.5 Number and Type of Test Specimens and Range of Thickness Qualified—WPS Qualification—PJP Groove Welds	28
3.6 Number and Type of Test Specimens and Range of Thickness Qualified—WPS Qualification—Fillet Welds	29
3.7 Welder Performance Qualification—Type of Weld and Position Limitations	30
3.8 Number and Type of Test Specimens and Range of Thickness Qualified—Welder and Welding Operator Qualification	31
3.9 Welding Personnel Performance Essential Variable Changes Requiring Requalification	35
4.1 Aluminum Alloy Products Available for Structural Applications	72
4.2 Recommended Aluminum Alloy Filler Metals for Structural Welding of Various Base Aluminum Alloys	73
4.3 Limit of Acceptability and Repair of Cut Edge Discontinuities in Plate	74
4.4 Technique	74
4.5 Maximum <u>Holding Times for Forming and Straightening</u>	75
4.6 <u>Weld Appearance</u>	76
5.1 Hole-Type IQI Requirements.	87
5.2 Wire IQI Requirements	87
5.3 Maximum Acceptable <u>Discontinuity</u> in Radiographs for Any 3 in [75 mm] Length of Weld (<u>Tubular and Cyclically Loaded Nontubular Connections</u>)	88
6.1 Minimum Required Torque Values and Tension Loads for Welding F-22 Aluminum-Alloy Studs	101
6.2 Stud Alloys for Arc Stud Welding of Various Base Alloys	101
6.3 Stud Alloys for Capacitor Discharge Stud Welding of Various Base Alloys	101
<u>K.1</u> Typical Current Ranges for Tungsten Electrodes	171
<u>K.2</u> Typical Chemical Composition of Tungsten Electrodes	172

List of Figures

Figure	Page No.
2.1	Details of Skewed T-Joints 7
2.2	Filler Plates Less Than 1/4 in [6 mm] in Thickness 8
2.3	Filler Plates 1/4 in [6 mm] or More in Thickness 8
3.1	Positions of Groove Welds 36
3.2	Positions of Fillet Welds 37
3.3	Positions of Test Plates for Groove Welds 38
3.4	Positions of Test Pipes for Groove Welds 39
3.5	Positions of Test Plates for Fillet Welds 40
3.6	Positions of Test Pipes for Fillet Welds 41
3.7	Reduced Section Tension Specimens—Plate and Pipe 42
3.8	Alternate Reduced Section Tension Specimen for Pipe (3 in [75 mm] Diameter or Less) 43
3.9	Full Section Tension Specimens—Small Diameter Pipe (3 in [75 mm] Diameter or Less) 43
3.10	Transverse Side Bend Specimens 44
3.11	Longitudinal Face and Root Bend Specimens 45
3.12	Transverse Face and Root Bend Specimens 46
3.13	Wraparound Guided Bend Jig 47
3.14	Plunger-Type Guided Bend Jig 48
3.15	Roller-Type Guided Bend Jig 50
3.16	Nick-Break Fracture Test Specimen for WPS Qualification of Cast to Cast or Cast to Wrought Alloys 52
3.17	Fillet Weld Soundness Test for WPS Qualification—Option 1—Plate 53
3.18	Fillet Weld Soundness Test for WPS Qualification—Pipe 54
3.19	Fillet Weld Soundness Test for WPS Qualification—Option 2—Root Bend Test—Plate 55
3.20	Location of Test Specimens for WPS Qualification—Plate 56
3.21	Location of Test Specimens for WPS Qualification—Pipe 57
3.22	Location of Test Specimens for WPS Qualification—Box Tubing 57
3.23	Location of Test Specimens for WPS Qualification—Job Size Pipe or Tubing 1/16 in through 3/8 in [2 mm through 10 mm] Wall Thickness 58
3.24	Location of Test Specimens for WPS Qualification—Job Size Pipe or Tubing over 3/8 in [10 mm] Wall Thickness 58
3.25	Performance Qualification in All Positions—Plate Thickness $T \leq 1/8$ in [3 mm] 59
3.26	Performance Qualification in All Positions—Plate Thickness $T > 1/8$ in [3 mm] 59
3.27	Performance Qualification in the Horizontal Position—Plate Thickness $T > 1/8$ in [3 mm] 60
3.28	Alternative Groove Weld Qualification Test Plate: All Thicknesses 60
3.29	Tubular Groove Weld—Performance Qualification—Without Backing 61
3.30	Tubular Groove Weld—Performance Qualification—Without Backing (Alternative to Figure 3.29) 61
3.31	Tubular Groove Weld—Performance Qualification—With Backing 61
3.32	Fillet Weld or Tack Welder Performance Qualification—Plate 62
3.33	Fillet Weld or Tack Welder Performance Qualification—Pipe or Tubing 62
3.34	Location of Test Specimens on Welded Test Pipe and Box Tubing—Performance Qualification 63
4.1	Edge Discontinuities in Cut Plate 77
4.2	Acceptable and Unacceptable Weld Profiles 78
5.1	Radiographic Identification and Hole-Type or Wire IQI Locations on Approximately Equal Thickness Joints 10 in [250 mm] and Greater in Length 89
5.2	Radiographic Identification and Hole-Type or Wire IQI Locations on Approximately Equal Thickness Joints Less than 10 in [250 mm] in Length 90

Figure	Page No.
5.3 Radiographic Identification and Hole-Type or Wire IQI Locations on Transition Joints 10 in [250 mm] and Greater in Length	91
5.4 Radiographic Identification and Hole-Type or Wire IQI Locations on Transition Joints Less Than 10 in [250 mm] in Length	92
5.5 Hole-Type IQI Design	93
5.6 Wire IQI	95
5.7 <u>Radiographic</u> Edge Blocks.....	96
5.8 <u>Maximum Acceptable Discontinuity RT Images</u>	96
6.1 Stud Weld Bend Jig	102
6.2 Torque Testing Arrangement for Stud Welds.....	103
 <i>Annexes</i>	
B.1 Recommended CJP Groove Welded Joints	110
<u>B.2 Recommended PJP Groove Welded Joints</u>	130
<u>B.3</u> PJP Box Connections	141
<u>B.4</u> PJP—Circular—Tubular Joints for T-, Y-, and K-Connections Made by GTAW and GMAW.....	142
<u>D.1</u> Examples of Tubular Connections.....	146
<u>E.1</u> Effective Throats of PJP Groove Welds Reinforced with Fillet Welds	149
 <i>Commentary</i>	
C-4.1 Examples of Unacceptable Cutting Beyond the Point of Tangency.....	188
C-4.2 Permissible Offset in Abutting Members	188
C-4.3 Correction of Misaligned Members	189
C-4.4 Measurement of Flange Warpage and Tilt	189

Structural Welding Code—Aluminum

1. General Requirements

1.1 Scope

This code contains the requirements for fabricating and erecting welded aluminum structures. When this code is stipulated in the contract documents, conformance with all provisions of the code shall be required, except those provisions that the Engineer or contract documents specifically modifies or specifically exempts.

Safety and health issues and concerns are beyond the scope of this standard and therefore are not fully addressed herein. Safety and health information is available from other sources, including, but not limited to, ANSI Z49.1, Safety in Welding, Cutting, and Allied Processes, and applicable federal, state, and local regulations.

1.1.1 Limitations. This code is not intended for specialized fabrication such as pressure vessels or pressure piping.

1.1.2 Alternate Requirements. Alternate requirements from those in this code shall be submitted to the Engineer for approval. These requirements shall be based on experience, experimental evidence, or engineering analyses, and shall consider materials, loads, and environment.

1.2 Approval

All references to the need for approval shall be interpreted to mean approval by the Building Commissioner or the Engineer. Hereinafter, the term *Engineer* shall be used, and is to be construed to mean the Building Commissioner or the Engineer.

1.3 Definitions

The welding terms used in this code shall be interpreted in conformance with the definitions given in the latest edition of AWS A3.0, Standard Welding Terms and Definitions, Including Terms for Adhesive Bonding, Brazing, Soldering, Thermal Cutting, and Thermal Spraying.

1.4 Welding Symbols

Welding symbols shall be those shown in the latest edition of AWS A2.4, *Standard Symbols for Welding, Brazing, and Nondestructive Examination*. Special conditions shall be fully explained by added notes or details.

1.5 Safety Precautions

This technical document does not address all welding and health hazards. However, pertinent information can be found in the following documents:

- (1) ANSI Z49.1, *Safety in Welding, Cutting, and Allied Processes*
- (2) Manufacturer's safety literature on equipment and materials
- (3) Other pertinent documents as appropriate.

These documents shall be referred to and followed as required (also see Annex J, Safe Practices).

NOTE: This code may involve hazardous materials, operations, and equipment. The code does not purport to address all of the safety problems associated with its use. It is the responsibility of the user to establish appropriate safety and health practices. The user should determine the applicability of any regulatory limitations prior to use.

1.6 Standard Units of Measure

This standard makes use of both U.S. Customary Units and the International System of Units (SI). The measurements may not be exact equivalents; therefore, each system shall be used independently of the other without combining in any way. The standard with the designation D1.2:2008 uses U.S. Customary Units. The standard designation D1.2M:2008 uses SI Units. The latter are shown within brackets [] or in appropriate columns in tables and figures.

1.7 Reference Documents

Annex A contains a list of all documents referenced in this code.